



Via Vicenza 45  
31050 VEDELAGO (TV)  
Tel 0423 400621  
Fax 0423 401177

## CERTIFICATE OF CONFORMITY: COPPER TUBE COATED WITH CROSS LINKED PE FOAM

In accordo con: EN 10204 -2.2

**CUSTOMER**

PTACEK

**ITEM CODE**

2RGC2GRE#GC100AE100

### COPPER TUBE

St N°: 2326 + 3272

**NOMINAL DIMENSION [mm]**

3/8x1,00-5/8x1,00x25MT

**NORM**

EN 12735-1

**ITEM NAME**

SUP. GREEN FS

**CHEMICAL COMPOSITION**

CU-DHP

**PHYSICAL STATE**

RICOTTO

**TENSILE STRENGTH**

220

> 220

**ELOGANTION**

40

> 40

**MARKING**

UNI IGQ P112 diam X wt EN 12735-1 FEINROHREN  
GREEN (R) ITALY ANNO TRIM CU-DHP

### CROSS LINKED PE FOAM

Code:  
037#A30B085064NAT  
+  
037#A30B085083NAT

**Propriety**

**Norm**

**Required**

**Result**

**DENSITY [Kg/m<sup>3</sup>]**

ISO 845

30

OK

**THICKNESS [mm]**

9 + 9

OK

**WATER VAPOR DIFFUSION  
RESISTANCE [μ]**

EN  
12086:2013

>9000

OK

**THERMAL CONDUCTIVITY  
AT 0°-40°C [W/m K]**

EN  
12667:2001

0,0377<λ<0,0435

OK

**MARKING**

<mt 99> GEL IGQ EN 12735-1 R410A-R32 Euroclasse  
Bs2d0 EN 13501-1 <logo CE> 3/8 - 1,0 X 5/8 -1,0  
<linea - data>

**THIS DOCUMENT CERTIFIES THAT THE PRODUCT COMPLIES WITH  
.THE AGREED SPECIFICATIONS**