



Via Vicenza 45
31050 VEDELAGO (TV)
Tel 0423 400621
Fax 0423 401177

CERTIFICATE OF CONFORMITY: COPPER TUBE COATED WITH CROSS LINKED PE FOAM

In accordo con: EN 10204 -2.2

CUSTOMER

PTACEK

ITEM CODE

2RGC2GRE#GA075AD075

COPPER TUBE

St N°: 385 + 387

NOMINAL DIMENSION [mm]

1/4x0,80 -1/2x0,80x25MT

NORM

EN 12735-1

ITEM NAME

SUP. GREEN FS

CHEMICAL COMPOSITION

CU-DHP

PHYSICAL STATE

RICOTTO

TENSILE STRENGTH

220

> 220

ELOGANTION

40

> 40

MARKING

UNI IGQ P112 diam X wt EN 12735-1 FEINROHREN
GREEN (R) ITALY ANNO TRIM CU-DHP

CROSS LINKED PE FOAM

Code:
037#A30B085054NAT
+
037#A30B085071NAT

Propriety

Norm

Required

Result

DENSITY [Kg/m³]

ISO 845

30

OK

THICKNESS [mm]

9 + 9

OK

WATER VAPOR DIFFUSION
RESISTANCE [μ]

EN
12086:2013

>9000

OK

THERMAL CONDUCTIVITY
AT 0°-40°C [W/m K]

EN
12667:2001

0,0377λ<0,0435

OK

MARKING

<mt 99> GEL IGQ EN 12735-1 R410A-R32 Euroclasse
Bs2d0 EN 13501-1 <logo CE> 1/4 - 0,8 X 1/2 -0,8
<linea - data>

**THIS DOCUMENT CERTIFIES THAT THE PRODUCT COMPLIES WITH
.THE AGREED SPECIFICATIONS**