



Via Vicenza 45  
31050 VEDELAGO (TV)  
Tel 0423 400621  
Fax 0423 401177

## CERTIFICATE OF CONFORMITY: COPPER TUBE COATED WITH CROSS LINKED PE FOAM

In accordo con: EN 10204 -2.2

CUSTOMER

PTACEK

ITEM CODE

2RGC2GRE#GA100AC100

### COPPER TUBE

St N°: 2325 + 2326

NOMINAL DIMENSION [mm]

1/4x1,00-3/8x1,00x25MT

NORM

EN 12735-1

ITEM NAME

SUP. GREEN FS

CHEMICAL COMPOSITION

CU-DHP

PHYSICAL STATE

RICOTTO

TENSILE STRENGTH

220

> 220

ELOGANTION

40

> 40

MARKING

UNI IGQ P112 diam X wt EN 12735-1 FEINROHREN  
GREEN (R) ITALY ANNO TRIM CU-DHP

### CROSS LINKED PE FOAM

Code:  
037#A30B085054NAT  
+  
037#A30B085064NAT

Propriety

Norm

Required

Result

DENSITY [Kg/m<sup>3</sup>]

ISO 845

30

OK

THICKNESS [mm]

9 + 9

OK

WATER VAPOR DIFFUSION  
RESISTANCE [μ]

EN  
12086:2013

>9000

OK

THERMAL CONDUCTIVITY  
AT 0°-40°C [W/m K]

EN  
12667:2001

0,0377<λ<0,0435

OK

MARKING

<mt 99> GEL IGQ EN 12735-1 R410A-R32 Euroclasse  
Bs2d0 EN 13501-1 <logo CE> 1/4-1,0 X 3/8-1,0 <linea -  
data>

**THIS DOCUMENT CERTIFIES THAT THE PRODUCT COMPLIES WITH  
.THE AGREED SPECIFICATIONS**