



Via Vicenza 45
31050 VEDELAGO (TV)
Tel 0423 400621
Fax 0423 401177

CERTIFICATE OF CONFORMITY: COPPER TUBE COATED WITH CROSS LINKED PE FOAM

In accordo con: EN 10204 -2.2

CUSTOMER

PTACEK

ITEM CODE

2RGCCGRE#GD100A

COPPER TUBE

St N°: 3270

NOMINAL DIMENSION [mm]

1/2" x 1,00 mm

NORM

EN 12735-1

ITEM NAME

GREEN

CHEMICAL COMPOSITION

CU-DHP

PHYSICAL STATE

ANNEALED

TENSILE STRENGTH

[MPa]

> 220

ELOGANTION

[%]

> 40

MARKING

UNI IGQ P112 1/2 X 1,00 EN 12735-1 FEINROHREN
GREEN (R) ITALY ANNO TRIM CU-DHP

CROSS LINKED PE FOAM

Code:

037#A30B085071NAT

Propriety

Norm

Required

Result

DENSITY [Kg/m³]

ISO 845

30

OK

THICKNESS [mm]

9

OK

**WATER VAPOR DIFFUSION
RESISTANCE [μ]**

EN
12086:2013

>9000

OK

**THERMAL CONDUCTIVITY
AT 0°-40°C [W/m K]**

EN
12667:2001

0,0377λ<0,0435

OK

MARKING

<mt 99> ZETAESSE CUPEX GEL Ø 1/2 X 1,00 EN
12735-1 UNI IGQ P112 Euroclass Bs2d0 EN 13501-1
<logo CE> R410A-R32 <linea - data>

**THIS DOCUMENT CERTIFIES THAT THE PRODUCT COMPLIES WITH
THE AGREED SPECIFICATIONS**