



Via Vicenza 45  
31050 VEDELAGO (TV)  
Tel 0423 400621  
Fax 0423 401177

## CERTIFICATE OF CONFORMITY: COPPER TUBE COATED WITH CROSS LINKED PE FOAM

In accordo con: EN 10204 -2.2

**CUSTOMER**

PTACEK

**ITEM CODE**

2RGCCGRE#GE100A

### COPPER TUBE

St N°: 3511

**NOMINAL DIMENSION [mm]**

5/8" x 1,00 mm

**NORM**

EN 12735-1

**ITEM NAME**

GREEN

**CHEMICAL COMPOSITION**

CU-DHP

**PHYSICAL STATE**

ANNEALED

**TENSILE STRENGTH**

[MPa]

> 220

**ELOGANTION**

[%]

> 40

**MARKING**

UNI IGQ P112 5/8 X 1,00 EN 12735-1 FEINROHREN  
GREEN (R) ITALY ANNO TRIM CU-DHP

### CROSS LINKED PE FOAM

Code:

037#A30B085054NAT

**Propriety**

**Norm**

**Required**

**Result**

**DENSITY [Kg/m<sup>3</sup>]**

ISO 845

30

OK

**THICKNESS [mm]**

11

OK

**WATER VAPOR DIFFUSION  
RESISTANCE [μ]**

EN  
12086:2013

>9000

OK

**THERMAL CONDUCTIVITY  
AT 0°-40°C [W/m K]**

EN  
12667:2001

0,0377<math>\lambda</math><0,0435

OK

**MARKING**

<mt 99> ZETAESSE CUPEX GEL Ø 5/8 X 1,00 EN  
12735-1 UNI IGQ P112 Euroclass Bs2d0 EN 13501-1  
<logo CE> R410A-R32 <linea - data>

**THIS DOCUMENT CERTIFIES THAT THE PRODUCT COMPLIES WITH  
THE AGREED SPECIFICATIONS**