



Via Vicenza 45  
31050 VEDELAGO (TV)  
Tel +39 423 400621  
Fax +39 423 401177

### CERTIFICATE OF CONFORMITY: COPPER TUBE COATED WITH CROSS LINKED PE FOAM

In accordo con: EN 10204 -2.2

**CUSTOMER**

PTACEK

**ITEM CODE**

2RGCCGRE#GF100B

### COPPER TUBE

St N°: 352

**NOMINAL DIMENSION [mm]**

3/4x1,00x50mt

**NORM**

EN 12735-1 / CUSTOMER'S  
SPECIFICATIONS

**ITEM NAME**

SUP. GREEN FS

**CHEMICAL COMPOSITION**

CU-DHP

**PHYSICAL STATE**

RICOTTO

**TENSILE STRENGTH**

220

> 220

**ELOGANTION**

40

> 40

**MARKING**

UNI IGQ P112 diam X wt EN 12735-1 FEINROHREN  
GREEN (R) ITALY ANNO TRIM CU-DHP

### CROSS LINKED PE FOAM

Code:

037#0A30B100105NAT

**Propriety**

**Norm**

**Required**

**Result**

**DENSITY [Kg/m<sup>3</sup>]**

ISO 845

30

OK

**THICKNESS [mm]**

11

OK

**WATER VAPOR DIFFUSION  
RESISTANCE [μ]**

EN  
12086:2013

>9000

OK

**THERMAL CONDUCTIVITY  
AT 0°-40°C [W/m K]**

EN  
12667:2001

0,0377<λ<0,0435

OK

**MARKING**

<mt 99> ZETAESSE CUPEX GEL Ø 3/4 X 1 EN 12735-1  
UNI IGQ P112 Euroclass Bs2d0 EN 13501-1 <logo CE>  
R410A-R32 <linea - data>

**THIS DOCUMENT CERTIFIES THAT THE PRODUCT COMPLIES WITH  
.THE AGREED SPECIFICATIONS**