



Via Vicenza 45
31050 VEDELAGO (TV)
Tel +39 423 400621
Fax +39 423 401177

**CERTIFICATE OF CONFORMITY: COPPER TUBE
COATED WITH CROSS LINKED PE FOAM**

In accordo con: EN 10204 -2.2

CUSTOMER

PTACEK

ITEM CODE

2RGCCGRE#GF100A

COPPER TUBE

St N°: 352

NOMINAL DIMENSION [mm]

3/4x1,00x25MT

NORM

EN 12735-1 / CUSTOMER'S
SPECIFICATIONS

ITEM NAME

SUP. GREEN FS

CHEMICAL COMPOSITION

CU-DHP

PHYSICAL STATE

RICOTTO

TENSILE STRENGTH

220

> 220

ELOGANTION

40

> 40

MARKING

UNI IGQ P112 diam X wt EN 12735-1 FEINROHREN
GREEN (R) ITALY ANNO TRIM CU-DHP

**CROSS LINKED
PE FOAM**

Code:

037#0A30B100105NAT

Propriety

Norm

Required

Result

DENSITY [Kg/m³]

ISO 845

30

OK

THICKNESS [mm]

11

OK

**WATER VAPOR DIFFUSION
RESISTANCE [μ]**

EN
12086:2013

>9000

OK

**THERMAL CONDUCTIVITY
AT 0°-40°C [W/m K]**

EN
12667:2001

0,0377<λ<0,0435

OK

MARKING

<mt 99> ZETAESSE CUPEX GEL Ø 3/4 X 1 EN 12735-1
UNI IGQ P112 Euroclass Bs2d0 EN 13501-1 <logo CE>
R410A-R32 <linea - data>

**THIS DOCUMENT CERTIFIES THAT THE PRODUCT COMPLIES WITH
.THE AGREED SPECIFICATIONS**