



Test settings:

Station 2

Starting pressure: 0,50 bar
 Step: 0,50 bar
 Stabilisation time: 5 "
 Steps number: 10

Open hot
 Open by-pass
 Open cold

Pitch	Hot pressure (bar)	Cold pressure (bar)	Hot flow rate (l/min)	Cold flow rate (l/min)	Mixed flow rate (l/min)	Mixed temperature (°C)
1	0,50	0,50	2,65	2,57	5,22	27,16
2	1,01	1,00	4,13	3,74	7,87	27,15
3	1,51	1,51	4,69	5,17	9,86	27,16
4	2,01	1,99	5,82	5,73	11,55	27,16
5	2,51	2,50	6,35	6,74	13,10	27,16
6	3,01	3,01	7,10	7,43	14,53	27,16
7	3,51	3,50	7,52	7,94	15,46	27,16
8	4,01	4,01	7,97	8,41	16,38	27,17
9	4,51	4,49	8,35	8,89	17,24	27,17
10	5,00	4,99	8,81	9,23	18,04	27,17